



**FIRE DEPARTMENT INSPECTION**

Apartment Building

Date: \_\_\_\_\_

Return this form when complete to \_\_\_\_\_ District Office \_\_\_\_\_  
 Address: \_\_\_\_\_

**IDENTIFYING INFORMATION** (Name of Foster Family)

Name: \_\_\_\_\_ Phone Number: \_\_\_\_\_  
 Street: \_\_\_\_\_  
 City: \_\_\_\_\_ State: \_\_\_\_\_ Zip Code: \_\_\_\_\_

The individual named above is applying for a foster family care license. In accordance with RSA 170-E, the local fire department shall conduct a review/inspection and apply the appropriate provisions for **existing apartment buildings** as outlined herein. Becoming a licensed foster family does not constitute a change of use of the home. Children placed with a foster family are not "tenants or outsiders".

**THIS FORM IS NOT INTENDED TO BE AN ALL-INCLUSIVE LIFE SAFETY/FIRE INSPECTION.**

		YES	NO
1.	The apartment shall have working smoke detectors/alarms installed and maintained as per manufacturer's recommendations.	<input type="checkbox"/>	<input type="checkbox"/>
2.	The apartment shall have working carbon monoxide detectors/alarms on each floor installed and maintained as per manufacturer's recommendations.	<input type="checkbox"/>	<input type="checkbox"/>
3.	The apartment building shall have at least two remote ways out from each floor level.	<input type="checkbox"/>	<input type="checkbox"/>
4.	No living spaces shall be accessible only by ladder or folding stairs.	<input type="checkbox"/>	<input type="checkbox"/>
5.	A window in the designated sleeping room of the apartment shall open to a size that allows an occupant to escape and firefighter to enter. (If the building is under four (4) stories in height).	<input type="checkbox"/>	<input type="checkbox"/>
6.	All the doors in the travel path to an exit shall be a minimum of 28 inches in width.	<input type="checkbox"/>	<input type="checkbox"/>
7.	All the closet doors in the apartment shall be operable from the inside.	<input type="checkbox"/>	<input type="checkbox"/>
8.	All electrical outlets, switches and junction boxes shall have covers.	<input type="checkbox"/>	<input type="checkbox"/>
9.	GFCI outlets (or circuits) shall be installed by all sinks, showers, and bathtubs.	<input type="checkbox"/>	<input type="checkbox"/>
10.	The apartment building shall be identified by a building number. The unit shall have a number to identify the unit.	<input type="checkbox"/>	<input type="checkbox"/>

**If any of the responses above are "NO", explain the plan to correct the problem**

Provisional Approval Granted on: \_\_\_\_\_ Re-Inspection of the Apartment will be on: \_\_\_\_\_

**This Apartment Meets the Requirements for a Foster Family Home on:** \_\_\_\_\_

Signed: \_\_\_\_\_  
*Fire Inspector* *Fire Department*

**RE-INSPECTION**

Problems were Corrected and the Apartment Meets the Foster Family Care Licensing Requirements on: \_\_\_\_\_

Signed: \_\_\_\_\_  
*Fire Inspector* *Fire Department*